



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al patrulea 2022

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **BRANESTI** – OCTOMBRIE 2022

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 188/06.12.2021	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7,5	-	-	1	0	6.5-8.5	SR ENISO 10523:2012
MTS		mg/l	14	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	10	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr		mg/l	31,33	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu fix		mg/l	778	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	1,68	-	-	1	1	0,5	SR EN 903:2003
Amoniu		mg/l	9,36	-	-	1	1	3,0	SR EN ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1380/25.10.2022



COMPANIA DE APA

TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **BRANESTI** –NOIEMBRIE 2022

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 188/06.12.2021	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7,5	-	-	1	0	6.5-8.5	SREN ISO 10523:2012
MTS		mg/l	5,4	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	4	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu fix		mg/l	130	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	0,1	-	-	1	0	0,5	SR EN 903:2003
Amoniu		mg/l	0,26	-	-	1	0	3,0	SR EN ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1503/15.11.2022



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **BRANESTI** –DECEMBRIE 2022

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 188/06.12.2021	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7,5	-	-	1	0	6.5-8.5	SR EN ISO 10523:2012
MTS		mg/l	7,4	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	7	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr		mg/l	31,13	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu fix		mg/l	327	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	0,39	-	-	1	0	0,5	SR EN 903:2003
Amoniu		mg/l	1,15	-	-	1	0	3,0	SR EN ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1623/14.12.2022