



# COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al patrulea 2022

Indicatori chimici monitorizati la IESIREA din Statia de Epurare FIENI OCTOMBRIE 2022

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	UM	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. Mas.	Nr.Depasiri CMA / VL	CMA / VL. conf. Autoriz. Mediu nr. 86 / 08.11.2016	Metoda Analiza STAS - ISO
pH	lesire statie	Unit. pH	7,7	–	–	1	0	6,5 – 8,5	SR EN ISO 10523: 2012
CCO – Cr.	lesire statie	mg / L	<30	–	–	1	0	500	SR ISO 6060: 1996
NH <sub>4</sub>	lesire statie	mg / L	0,12	–	–	1	0	30	SR ISO 7150-1: 2001
Agenti de suprafata anionici	lesire statie	mg / L	0,11	–	–	1	0	25	SR EN 903: 2003
MTS	lesire statie	mg / L	5,4	–	–	1	0	350	SR EN 872: 2005
Reziduu filtrabil	lesire statie	mg / L	498	–	–	1	0	2000	STAS 9187: 1984
CBO <sub>5</sub>	lesire statie	mg / L	3	–	–	1	0	300	SR EN ISO 5815-1:2020
SE	lesire statie	mg / L	<20	–	–	1	0	30	SR 7587: 1996

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1367/24.10.2022



# COMPANIA DE APA

## TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **FIENI**- NOIEMBRIE 2022

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	UM	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. Mas.	Nr.Depasiri CMA / VL	CMA / VL. conf. Autoriz. Mediu nr. 86 / 08.11.2016	Metoda Analiza STAS - ISO
pH	lesire statie	Unit. pH	7,6	–	–	1	0	6,5 – 8,5	SR EN ISO 10523: 2012
CCO – Cr.	lesire statie	mg / L	<30	–	–	1	0	500	SR ISO 6060: 1996
NH <sub>4</sub>	lesire statie	mg / L	0,43	–	–	1	0	30	SR ISO 7150-1: 2001
Agenti de suprafata anionici	lesire statie	mg / L	0,10	–	–	1	0	25	SR EN 903: 2003
MTS	lesire statie	mg / L	4,8	–	–	1	0	350	SR EN 872: 2005
Reziduu filtrabil	lesire statie	mg / L	321	–	–	1	0	2000	STAS 9187: 1984
CBO <sub>5</sub>	lesire statie	mg / L	5	–	–	1	0	300	SR EN ISO 5815-1:2020
SE	lesire statie	mg / L	<20	–	–	1	0	30	SR 7587: 1996

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1553/28.11.2022



# COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **FIENI** – DECEMBRIE 2022

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	UM	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. Mas.	Nr.Depasiri CMA / VL	CMA / VL. conf. Autoriz. Mediu nr. 130/10.11.2022	Metoda Analiza STAS - ISO
pH	lesire statie	Unit. pH	7,6	–	–	1	0	6,5 – 8,5	SR EN ISO 10523: 2012
CCO – Cr.	lesire statie	mg / L	32,69	–	–	1	0	500	SR ISO 6060: 1996
NH <sub>4</sub>	lesire statie	mg / L	0,44	–	–	1	0	30	SR ISO 7150-1: 2001
Agenti de suprafata anionici	lesire statie	mg / L	0,10	–	–	1	0	25	SR EN 903: 2003
MTS	lesire statie	mg / L	8,8	–	–	1	0	350	SR EN 872: 2005
Reziduu filtrabil	lesire statie	mg / L	592	–	–	1	0	2000	STAS 9187: 1984
CBO <sub>5</sub>	lesire statie	mg / L	6	–	–	1	0	300	SR EN ISO 5815-1:2020
SE	lesire statie	mg / L	<20	–	–	1	0	30	SR 7587: 1996

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare –nr. 1660/21.12.2022