



# COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al patrulea 2022

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **RACIU-OCTOMBRIE** 2022

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	AM nr. 64/11.12.2018 rev.24.02/2021	Metoda de analiza
pH	lesire statie	unitati ph	7,6	-	-	1	0	6,5-8,5	SR EN ISO 10523/2012
Consum chimic de oxigen		mg/l	<30	-	-	1	0	125	SR ISO 6060/1996
Amoniu		mg/l	0,08	-	-	1	0	3	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	0,11	-	-	1	0	0,5	SR EN 903/2003
Materii totale in suspensie		mg/l	5,4	-	-	1	0	60	SR EN 872/2005
Reziduu filtrabil		mg/l	452	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO <sub>5</sub> )		mg/l	4	-	-	1	0	25	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	< 20	-	-	1	0	20	SR 7587/1996

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – nr.1356/24.10.2022



# COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **RACIU-NOIEMBRIE 2022**

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	AM nr. 64/11.12.2018 rev.24.02/2021	Metoda de analiza
pH	lesire statie	unitati ph	7,5	-	-	1	0	6.5-8.5	SR EN ISO 10523/2012
Consum chimic de oxigen		mg/l	<30	-	-	1	0	125	SR ISO 6060/1996
Amoniu		mg/l	0,40	-	-	1	0	3	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	0,16	-	-	1	0	0,5	SR EN 903/2003
Materii totale in suspensie		mg/l	6	-	-	1	0	60	SR EN 872/2005
Reziduu filtrabil		mg/l	232	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO <sub>5</sub> )		mg/l	4	-	-	1	0	25	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	20	SR 7587/1996

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – nr. 1460/09.11.2022



# COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **RACIU-DECEMBRIE 2022**

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	AM nr. 64/11.12.2018 rev.24.02/2021	Metoda de analiza
pH	Iesire statie	unitati ph	7,6	-	-	1	0	6.5-8.5	SR EN ISO 10523/2012
Consum chimic de oxigen		mg/l	<30	-	-	1	0	125	SR ISO 6060/1996
Amoniu		mg/l	0,27	-	-	1	0	3	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	0,26	-	-	1	0	0,5	SR EN 903/2003
Materii totale in suspensie		mg/l	5,8	-	-	1	0	60	SR EN 872/2005
Reziduu filtrabil		mg/l	382	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO <sub>5</sub> )		mg/l	4	-	-	1	0	25	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	20	SR 7587/1996

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – nr.1664/21.12.2022