



# COMPANIA DE APA

## TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

### REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al patrulea 2022

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **RASCAETI** - OCTOMBRIE 2022

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr.8868 din 12.10.2012	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,5	-	-	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO-Cr	lesire statie	mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	0,28	-	-	1	0	3	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	<0,1	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	5	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	259	-	-	1	0	1000	STAS 9187:1984
CBO5	lesire statie	mg/l	4	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta extractibila	lesire statie	mg/l	<20	-	-	1	0	20	SR 7587:1996
Fosfor total	lesire statie	mg/l	0,16	-	-	1	0	2	SR EN ISO 6878:2005

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1330/18.10.2022



# COMPANIA DE APA

## TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **RASCAETI** - NOIEMBRIE 2022

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr.8868 din12.10.2012	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,5	-	-	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO-Cr	lesire statie	mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	0,19	-	-	1	0	3	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	0,12	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	5	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	250	-	-	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	4	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta extractibila	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587:1996
Fosfor total	lesire statie	mg/l	0,21	-	-	1	0	2	SR EN ISO 6878:2005

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – nr.1527/21.11.2022



# COMPANIA DE APA

## TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **RASCAETI** - DECEMBRIE 2022

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr.8868 din12.10.2012	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,5	-	-	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO-Cr	lesire statie	mg/l	32,80	-	-	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	0,42	-	-	1	0	3	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	<0,1	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	8,2	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	358	-	-	1	0	1000	STAS 9187:1984
CBO5	lesire statie	mg/l	8	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta extractibila	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587:1996
Fosfor total	lesire statie	mg/l	0,21	-	-	1	0	2	SR EN ISO 6878:2005

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1654/20.12.2022