



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al patrulea 2022

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **SPITAL DE PSIHIATRIE CRONICI GURA OCNITEI-OCTOMBRIE 2022**

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Val inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	CMA AM nr. 8853/20.09.2012	Metoda de analiza
pH	lesire statie	unitati ph	8	-	-	1	0	6,5-8,5	SR ISO 10523/2012
Consum chimic de oxigen		mg O ₂ /l	193,92	-	-	1	0	500	SR ISO 6060/1996
Amoniu		mg/l	34,52	-	-	1	1	30	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	2,34	-	-	1	0	25	SR EN 903/2003
Materii totale in suspensie		mg/l	66	-	-	1	0	350	SR EN 872/2005
Reziduu filtrabil		mg/l	763	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)		mg O ₂ /l	103	-	-	1	0	300	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	30	SR 7587/1996
Fosfor total		mg/l	4,96	-	-	1	0	5	SR EN ISO 6878/2005
Cloruri		mg/l	160	-	-	1	0	500	SR EN ISO 10304-1/2009

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1319/17.10.2022



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **SPITAL DE PSIHIATRIE CRONICI GURA OCNITEI-NOIEMBRIE 2022**

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Val inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	CMA AM nr. 115/24.10.2022	Metoda de analiza
pH	Iesire statie	unitati ph	7,8	-	-	1	0	6,5-8,5	SR ISO 10523/2012
Consum chimic de oxigen		mg O ₂ /l	179,73	-	-	1	0	500	SR ISO 6060/1996
Amoniu		mg/l	40,31	-	-	1	1	30	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	3,19	-	-	1	0	25	SR EN 903/2003
Materii totale in suspensie		mg/l	54	-	-	1	0	350	SR EN 872/2005
Reziduu filtrabil		mg/l	773	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)		mg O ₂ /l	115	-	-	1	0	300	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	30	SR 7587/1996
Fosfor total		mg/l	5,91	-	-	1	1	5	SR EN ISO 6878/2005
Cloruri		mg/l	41	-	-	1	0	500	SR EN ISO 10304-1/2009

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare –nr. 1476/14.11.2022



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **SPITAL DE PSIHIATRIE CRONICI GURA OCNITEI-DECEMBRIE 2022**
Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Val inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	CMA AM nr. 115/24.10.2022	Metoda de analiza
pH	Iesire statie	unitati ph	8	-	-	1	0	6,5-8,5	SR ISO 10523/2012
Consum chimic de oxigen		mg O ₂ /l	289,68	-	-	1	0	500	SR ISO 6060/1996
Amoniu		mg/l	28,40	-	-	1	0	30	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	1,90	-	-	1	0	25	SR EN 903/2003
Materii totale in suspensie		mg/l	90	-	-	1	0	350	SR EN 872/2005
Reziduu filtrabil		mg/l	784	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)		mg O ₂ /l	217	-	-	1	0	300	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	30	SR 7587/1996
Fosfor total		mg/l	6,20	-	-	1	1	5	SR EN ISO 6878/2005
Cloruri		mg/l	50	-	-	1	0	500	SR EN ISO 10304-1/2009

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare –nr. 1647/19.12.2022