



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al patrulea 2022

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **VULCANA PANDELE** – OCTOMBRIE 2022

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 56/08.04.2019	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7,7	-	-	1	0	6,5-8,5	SR EN ISO 10523:2012
MTS		mg/l	17	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	24	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	69,24	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	816	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	2,18	-	-	1	1	0,5	SR EN 903:2003
Amoniu		mg/l	23,57	-	-	1	1	3	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1362 / 24.10.2022



COMPANIA DE APA

TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **VULCANA PANDELE** – NOIEMBRIE 2022

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 56/08.04.2019	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7,6	-	-	1	0	6.5-8.5	SR ENISO 10523:2012
MTS		mg/l	16	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	22	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	62,36	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	267	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	1,74	-	-	1	1	0,5	SR EN 903:2003
Amoniu		mg/l	22,60	-	-	1	1	3,0	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 1505/15.11.2022



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **VULCANA PANDELE** – DECEMBRIE 2022

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 56/08.04.2019	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7,7	-	-	1	0	6.5-8.5	SR EN ISO 10523:2012
MTS		mg/l	13	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	48	-	-	1	1	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	101,67	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	792	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	4,47	-	-	1	1	0,5	SR EN 903:2003
Amoniu		mg/l	39,73	-	-	1	1	3	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – nr.1598/12.12.2022