



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL II 2025

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **TARGOVISTE SUD - IULIE, AUGUST, SEPTEMBRIE 2025**

Tip proba-apa uzata

Indicatori de analiza	Punct de prelevare	UM	Val Inregistr.	Val Inregistr.	Val Inregistr.	Nr. masuratori	Nr. dep CMA	CMA cfm. A.M. nr.124/14.07.2014 rev 14.07.2023 AGA nr. 99C/01.12.2024	Metoda de analiza
			iulie	august	septembrie				
pH	lesire Statie	Unitati pH	7,6	7,6	7,5	1	0	6,5-8,5	SR ISO 10523:2012
Consum chimic de oxigen	lesire Statie	mg/L	<30	31,16	<30	1	0	125	PSL-06,Ed.IV,Rev.1/13.01.2025
Amoniu	lesire Statie	mg/L	-	1,8	-	-	-	3,0	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire Statie	mg/L	0,11	0,15	<0,1	1	0	0,5	SR EN 903:2003
Materii totale in suspensie	lesire Statie	mg/L	9,8	8,2	8,4	1	0	35	SR EN 872:2005
Reziduu filtrabil	lesire Statie	mg/L	983	358	824	1	0	2000	STAS 9187:1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)	lesire Statie	mg/L	3	4	5	1	0	25	SR EN ISO 5815-1:2020
Substante extractibile	lesire Statie	mg/L	<20	<20	<20	1	0	20	SR 7587:1996
Fosfor total	lesire Statie	mg/L	1,98	0,84	1,92	1	0	1,0	SR EN ISO 6878:2005
Azot total	lesire Statie	mg/L	13	15	5,5	1	0	10	SR EN ISO 20236:2021
Azotati	lesire Statie	mg/L	-	50	-	1	1	37	SR EN ISO 10304-1:2009
Azotiti	lesire Statie	mg/L	-	<0,05	-	1	0	2,0	SR EN ISO 10304-1:2009
Indice de fenol	lesire Statie	mg/L	<0,1	-	<0,1	1	0	0,3	SR EN ISO 6439:2006
Nichel	lesire Statie	mg/L	0,1	-	<0,1	1	0	0,5	SR EN ISO 8288:2001
Zinc	lesire Statie	mg/L	<0,05	-	<0,05	1	0	0,5	SR EN ISO 8288:2001
Crom total	lesire Statie	mg/L	<0,5	-	<0,5	1	0	1,0	SR EN ISO 1233:2003
Cupru	lesire Statie	mg/L	<0,05	-	<0,05	1	0	0,2	SR EN ISO 8288:2001
Cadmiu	lesire Statie	mg/L	<0,02	-	0,02	1	0	0,2	SR EN ISO 8288:2001



COMPANIA DE APA
TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 **0800800168** (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform rapoartelor de incercare Nr. 1003/22.07.2025, Nr. 1146/25.08.2025, Nr. 794/16.06.2025, Nr. 1229/09.09.2025