

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL IV 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **VISINESTI**- OCTOMBRIE 2024

Tip proba-apa uzata

Indicator analizat	Punct de Prelevare	U.M	Val Inregistr.	Val Max.	Val Min.	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conf.AM 46/24.03.2020 AGA nr. 48/03.11.2021	Metoda de analiza
Ph	lesire statie	Unitati Ph	8	-	-	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS	lesire statie	Mg/l	8,2	-	-	1	0	35	SR EN 872/2005
CBO ₅	lesire statie	mg/l	5	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr	lesire statie	mg/l	32,86	-	-	1	0	125	SR EN ISO 6060/1996
SE	lesire statie	Mg/l	<20	-	-	1	0	20	SR ISO 7587/1996
Reziduu fix	lesire statie	Mg/l	418	-	-	1	0	2000	STAS 9187/84
Detergenti	lesire statie	Mg/l	0,11	-	-	1	0	0,5	SR EN 903/2003
Amoniu	lesire statie	Mg/l	0,37	-	-	1	0	3	SR ISO 7150-1/2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare –nr. 1521/15.10.2024