

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **BRANESTI** -IANUARIE 2024

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 188/06.12.2021	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7,5	-	-	1	0	6.5-8.5	SR ENISO 10523:2012
MTS		mg/l	7,2	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	4	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr		mg/l	30,90	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu fix		mg/l	628	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	0,31	-	-	1	0	0,5	SR EN 903:2003
Amoniu		mg/l	0,32	-	-	1	0	3,0	SR EN ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare - Nr. 75/22.01.2024

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **BRANESTI** -MARTIE 2024

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 188/06.12.2021	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7,8	-	-	1	0	6.5-8.5	SR ENISO 10523:2012
MTS		mg/l	7	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	4	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu fix		mg/l	137	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	<0,1	-	-	1	0	0,5	SR EN 903:2003
Amoniu		mg/l	0,26	-	-	1	0	3,0	SR EN ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare - Nr.365/12.03.2024