

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **BREZOAELE**- IANUARIE 2024


Tip proba-apa uzata

| Indicator de analiza         | Punct de Prelevare | U.M     | Valoare inregistrata | Valoare maxima | Valoare minima | Numar masurat ori | Nr.depa siri CMA / VL | CMA/VL conform autorizatiei de mediu Nr.84/17. 05. 2019 Rev.07.06.2021 | Metoda de analiza     |
|------------------------------|--------------------|---------|----------------------|----------------|----------------|-------------------|-----------------------|--|-----------------------|
| PH                           | lesire statie      | Unit/PH | 7,4                  | -              | -              | 1                 | 0                     | 6,5-8,5  | SR EN ISO10523-2012   |
| CCO-CR                       | lesire statie      | mg/l    | 31,26                | -              | -              | 1                 | 0                     | 125  | SR ISO 6060/1996      |
| Agenti de suprafata anionici | lesire statie      | mg/l    | 0,19                 | -              | -              | 1                 | 0                     | 0,5  | SR EN 903:2003        |
| MTS                          | lesire statie      | mg/l    | 6,2                  | -              | -              | 1                 | 0                     | 35   | SR EN 872:2005        |
| Reziduu filtrabil            | lesire statie      | mg/l    | 347                  | -              | -              | 1                 | 0                     | 2000   | STAS 9187:1984        |
| CBO5                         | lesire statie      | mg/l    | 4                    | -              | -              | 1                 | 0                     | 25   | SR EN ISO 5815-1:2020 |
| Substanta Extractibila       | lesire statie      | mg/l    | < 20                 | -              | -              | 1                 | 0                     | 20   | SR 7587:1996          |
| Amoniu                       | lesire statie      | mg/l    | 0,88                 | -              | -              | 1                 | 0                     | 2  | SR ISO 7150-1:2001    |

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare - Nr.106/29.01.2024



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **BREZOAELE-FEBRUARIE 2024**


Tip proba-apa uzata

| Indicator de analiza         | Punct de Prelevare | U.M     | Valoare inregistrata | Valoare maxima | Valoare minima | Numar masurat ori | Nr.depa siri CMA / VL | CMA/VL conform autorizatiei de mediu Nr.84/17. 05. 2019 Rev.07.06.2021 | Metoda de analiza     |
|------------------------------|--------------------|---------|----------------------|----------------|----------------|-------------------|-----------------------|--|-----------------------|
| PH                           | lesire statie      | Unit/PH | 8,3                  | -              | -              | 1                 | 0                     | 6,5-8,5  | SR EN ISO10523-2012   |
| CCO-CR                       | lesire statie      | mg/l    | 33,32                | -              | -              | 1                 | 0                     | 125  | SR ISO 6060/96        |
| Agenti de suprafata anionici | lesire statie      | mg/l    | 0,20                 | -              | -              | 1                 | 0                     | 0,5  | SR EN 903:2003        |
| MTS                          | lesire statie      | mg/l    | 11                   | -              | -              | 1                 | 0                     | 35   | SR EN 872:2005        |
| Reziduu filtrabil            | lesire statie      | mg/l    | 671                  | -              | -              | 1                 | 0                     | 2000   | STAS 9187:1984        |
| CBO5                         | lesire statie      | mg/l    | 5                    | -              | -              | 1                 | 0                     | 25   | SR EN ISO 5815-1:2020 |
| Substanta Extractibila       | lesire statie      | mg/l    | <20                  | -              | -              | 1                 | 0                     | 20   | SR 7587:1996          |
| Amoniu                       | lesire statie      | mg/l    | 0,29                 | -              | -              | 1                 | 0                     | 2  | SR ISO 7150-1:2001    |

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform raport de incercare nr.176/12.02.2024



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **BREZOAELE- MARTIE 2024**

Tip proba-apa uzata

| Indicator de analiza         | Punct de Prelevare | U.M     | Valoare inregistrata | Valoare maxima | Valoare minima | Numar masurat ori | Nr.depasiri CMA / VL | CMA/VL conform autorizatiei de mediu Nr.84/17. 05. 2019 Rev.07.06.2021 | Metoda de analiza     |
|------------------------------|--------------------|---------|----------------------|----------------|----------------|-------------------|----------------------|--|-----------------------|
| PH                           | lesire statie      | Unit/PH | 7,1                  | -              | -              | 1                 | 0                    | 6,5-8,5  | SR EN ISO 10523-2012  |
| CCO-CR                       | lesire statie      | mg/l    | <30                  | -              | -              | 1                 | 0                    | 125  | SR ISO 6060/96        |
| Agenti de suprafata anionici | lesire statie      | mg/l    | 0,38                 | -              | -              | 1                 | 0                    | 0,5  | SR EN 903:2003        |
| MTS                          | lesire statie      | mg/l    | 5,6                  | -              | -              | 1                 | 0                    | 35   | SR EN 872:2005        |
| Reziduu filtrabil            | lesire statie      | mg/l    | 224                  | -              | -              | 1                 | 0                    | 2000   | STAS 9187:1984        |
| CBO5                         | lesire statie      | mg/l    | 7                    | -              | -              | 1                 | 0                    | 25   | SR EN ISO 5815-1:2020 |
| Substanta Extractibila       | lesire statie      | mg/l    | <20                  | -              | -              | 1                 | 0                    | 20   | SR 7587:1996          |
| Amoniu                       | lesire statie      | mg/l    | 1,26                 | -              | -              | 1                 | 0                    | 2  | SR ISO 7150-1:2001    |

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform raport de incercare nr. 406/19.03.2024