

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovită

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **COMISANI-FEBRUARIE 2024**


Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val Maxima	Val Minima	Nr. Mas	Nr. Dep. CMA	CMA AM nr. 8404/12.01.2011 Rev.13.04.2022	Metoda de analiza
pH	Iesire Statie	unitati ph	7,4	-	-	1	0	6.5-8.5	SR ISO 10523/2012
Consum chimic de oxigen		mg/l	31,13	-	-	1	0	125	SR ISO 6060/1996
Amoniu		mg/l	0,66	-	-	1	0	3	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	0,14	-	-	1	0	0,5	SR EN 903/2003
Materii totale in suspensie		mg/l	6,2	-	-	1	0	60	SR EN 872/2005
Reziduu filtrabil		mg/l	348	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)		mg/l	7	-	-	1	0	25	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	20	SR 7587/1996

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare -nr. 199/14.02.2024



COMPANIA DE APA
TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 **0800800168** (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro