

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **IONESTI** - IANUARIE 2024

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr.149/12.12.2022 rev.28.09.2023	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,7	-	-	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO-Cr	lesire statie	mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	0,55	-	-	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	0,18	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	5,8	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	327	-	-	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	6	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta extractibila	lesire statie	mg/l	<20	-	-	1	0	20	SR 7587:1996
Produs petrolier	lesire statie	mg/l	<0,1	-	-	1	0	5(fara irizatii)	SR 7877-2:1995

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Rapoart e de incercare - Nr.136/05.02.2024 si nr.157- AINS/02.02.2024

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **IONESTI** -FEBRUARIE 2024

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr.149/12.12.2022 rev.28.09.2023	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,9	-	-	1	0	6,5 - 8,5	SR ISO 10523/2012
CCO-Cr	lesire statie	mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	0,08	-	-	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	0,33	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	6	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	329	-	-	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	4	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta extractibila	lesire statie	mg/l	<20	-	-	1	0	20	SR 7587:1996
Produs petrolier	lesire statie	mg/l	-	-	-	-	0	5(fara irizatii)	SR 7877-2:1995

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Rapoart e de incercare - Nr. 225/19.02.2024

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **IONESTI** - MARTIE 2024


Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr.149/12.12.2022 rev.28.09.2023	Metoda de analiza (STAS,ISO)
Ph	lesire statie	Unitati pH	7,3	-	-	1	0	6,5 - 8,5	SR ISO 10523/2012
CCO-Cr	lesire statie	mg/l	31,18	-	-	1	0	125	SR ISO 6060:1996
Amoniu	lesire statie	mg/l	0,43	-	-	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	lesire statie	mg/l	<0,1	-	-	1	0	0,5	SR EN 903:2003
MTS	lesire statie	mg/l	10	-	-	1	0	60	SR EN 872:2005
Reziduu filtrabil	lesire statie	mg/l	339	-	-	1	0	2000	STAS 9187:1984
CBO5	lesire statie	mg/l	3	-	-	1	0	25	SR EN ISO 5815-1:2020
Substanta extractibila	lesire statie	mg/l	<20	-	-	1	0	20	SR 7587:1996
Produs petrolier	lesire statie	mg/l	-	-	-	-	0	5(fara irizatii)	SR 7877-2:1995

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Rapoart e de incercare - Nr.458/28.03.2024



**COMPANIA DE APA**  
TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

---

Tel. +40245.614403 **0800800168** (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)