

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL II 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **MORENI** – APRILIE, MAI, IUNIE 2024


Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare Inregistr.	Valoare Inregistr.	Valoare Inregistr.	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conform AM 140/17.11.2022	Metoda de analiza
			aprilie	mai	iunie				
Ph	lesire statie	Unitati Ph	6,9	7,5	7,8	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS	lesire statie	Mg/l	6,6	9,6	14	1	0	35	SR EN 872/2005
CBO ₅	lesire statie	mgO ₂ /dm ³	6	6	6	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr	lesire statie	mgO ₂ /dm ³	36,27	36,51	33,18	1	0	125	SR EN ISO 6060/1996
SE	lesire statie	Mg/l	<20	<20	<20	1	0	20	SR ISO 7587/1996
Reziduu fix	lesire statie	Mg/l	535	573	563	1	0	2000	STAS 9187/1984
Detergenti	lesire statie	Mg/l	<0,1	<0,1	<0,1	1	0	0,5	SR EN 903/2003
Fosfor total	lesire statie	Mg/l	0,70	0,62	1,25	1	0	2	SR EN ISO 6878/2005
Azot total	lesire statie	Mg/l	8,9	10	8,1	1	0	15	SR EN ISO 20236/2021

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr. 597/22.04.2024, Nr. 743/22.05.2024, Nr. 877/19.09.2024



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **MORENI** – FEBRUARIE 2024


Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conform AM 140/17.11.2022	Metoda de analiza
Ph	lesire statie	Unitati Ph	7,5(20,0°C)	-	-	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS	lesire statie	Mg/l	10	-	-	1	0	35	SR EN872/2005
CBO ₅	lesire statie	mgO ₂ /dm ³	7	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr	lesire statie	mgO ₂ /dm ³	34,73	-	-	1	0	125	SR EN ISO 6060/1996
SE	lesire statie	Mg/l	<20	-	-	1	0	20	SR ISO 7587/1996
Reziduu fix	lesire statie	Mg/l	513	-	-	1	0	2000	STAS 9187/1984
Detergenti	lesire statie	Mg/l	0,39	-	-	1	0	0,5	SR EN 903/2003
Fosfor total	lesire statie	Mg/l	1,5	-	-	1	0	2	SR EN ISO 6878/2005
Azot total	lesire statie	Mg/l	6,4	-	-	1	0	15	SR EN ISO 20236/2021

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare nr.239/20.02.2024



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **MORENI – MARTIE 2024**

Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conf.AM 140/17.11.2022	Metoda de analiza
Ph	lesire statie	Unitati Ph	7,7 (20,0°C)	-	-	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS	lesire statie	Mg/l	20	-	-	1	0	35	SR EN872/2005
CBO ₅	lesire statie	mgO ₂ /dm ³	12	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr	lesire statie	mgO ₂ /dm ³	50,92	-	-	1	0	125	SR EN ISO 6060/1996
SE	lesire statie	Mg/l	<20	-	-	1	0	20	SR ISO 7587/1996
Reziduu fix	lesire statie	Mg/l	512	-	-	1	0	2000	STAS 9187/1984
Detergenti	lesire statie	Mg/l	<0,1	-	-	1	0	0,5	SR EN 903/2003
Fosfor total	lesire statie	Mg/l	0,93	-	-	1	0	2	SR EN ISO 6878/2005
Azot total	lesire statie	Mg/l	7,7	-	-	1	0	15	SR EN ISO 20236/2021

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare nr. 367/12.03.2024