

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE **SEMESTRUL I 2024**

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **PARC INDUSTRIAL PRIBOIU – IUNIE 2024**

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AMnr.30/14.06.2018	Metoda de analiza (STAS, ISO)
pH	Iesire statie	unitati ph	7,6	-	-	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	<30	-	-	1	0	60	SR EN 872/2005
CBO ₅		mg/l	0,32	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	<0,1	-	-	1	0	125	SR ISO 6060/96
SE		mg/l	5	-	-	1	0	20	SR 7587/96
Reziduu fix		mg/l	328	-	-	1	0	2000	STAS 9187/84
Detergenti		mg/l	6	-	-	1	0	0,5	SR EN 903/2003
Fosfor total		mg/l	<20	-	-	1	1	2	SR EN ISO 6878/2005
Azot total		mg/l	0,09	-	-	1	1	15	SR EN ISO 20236:2021
Amoniu		mg/l	7,8	-	-	1	0	3	SR ISO 7150-1/2001
Azotati		mg/l	21	-	-	1	1	37	SR EN ISO 7890-3:2020
Cloruri		mg/l	2,6	-	-	1	0	500	SR EN ISO 10304-1/2009

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr.939/01.07.2024