

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **PUCIOASA** - IANUARIE 2024

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. Autorizatie Mediu Nr. 120/06.08.2019 Rev.14.07.2023	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7,1	-	-	1	0	6,5-8,5	SR EN ISO 10523:2012
MTS		mg/l	5,4	-	-	1	0	35	SR EN 872:2005
CBO <sub>5</sub>		mg/l	3	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	371	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	<0,1	-	-	1	0	0,5	SR EN 903:2003
Fosfor total		mg/l	0,12	-	-	1	0	2	SR EN ISO 6878:2005
Azot total		mg/l	3,4	-	-	1	0	15	SR EN ISO 20236:2021
Zinc		mg/l	-	-	-	-	-	0,5	SR EN ISO 11885-2009

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare - nr.30/15.01.2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **PUCIOASA** -FEBRUARIE 2024

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. Autorizatie Mediu Nr. 120/06.08.2019 Rev.14.07.2023	Metoda de analiza (STAS, ISO)
pH		Unitati ph	7,4	-	-	1	0	6.5-8.5	SR EN ISO 10523:2012
MTS		mg/l	9,6	-	-	1	0	35	SR EN 872:2005
CBO <sub>5</sub>		mg/l	9	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	42,45	-	-	1	0	125	SR ISO 6060:1996

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

SE	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	492	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	0,31	-	-	1	0	0,5	SR EN 903:2003
Fosfor total		mg/l	0,18	-	-	1	0	2	SR EN ISO 6878:2005
Azot total		mg/l	3	-	-	1	0	15	SR EN ISO 20236:2021
Zinc		mg/l	0,06	-	-	1	0	0,5	SR EN ISO 11885-2009

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare - Nr.231/20.02.2024 si nr. 250 AINS /12.02.2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **PUCIOASA** - MARTIE 2024

Tip proba-apa uzata



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. Autorizatie Mediu Nr. 120/06.08.2019 Rev.14.07.2023	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7,2	-	-	1	0	6.5-8.5	SR EN ISO 10523:2012
MTS		mg/l	8,2	-	-	1	0	35	SR EN 872:2005
CBO <sub>5</sub>		mg/l	11	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	48,96	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	< 20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	479	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	< 0,1	-	-	1	0	0,5	SR EN 903:2003
Fosfor total		mg/l	0,47	-	-	1	0	2	SR EN ISO 6878:2005
Azot total		mg/l	3,5	-	-	1	0	15	SR EN ISO 20236:2021

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform rapoartelor de incercare - nr.361/12.03.2024