

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **SPITAL DE PSIHIATRIE CRONICI GURA OCNITEI-IANUARIE 2024**

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Val inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	CMA AM nr. 115/24.10.2022	Metoda de analiza
pH	lesire statie	unitati ph	7,9	-	-	1	0	6,5-8,5	SR ISO 10523/2012
Consum chimic de oxigen		mg O ₂ /l	138,14	-	-	1	0	500	SR ISO 6060/1996
Amoniu		mg/l	19.06	-	-	1	0	30	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	3.46	-	-	1	0	25	SR EN 903/2003
Materii totale in suspensie		mg/l	39	-	-	1	0	350	SR EN 872/2005
Reziduu filtrabil		mg/l	600	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)		mg O ₂ /l	85	-	-	1	0	300	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	30	SR 7587/1996
Fosfor total		mg/l	2.76	-	-	1	0	5	SR EN ISO 6878/2005
Cloruri		mg/l	39	-	-	1	0	500	SR EN ISO 10304-1/2009

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare - Nr. 49/16.01.2024

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **SPITAL DE PSIHIATRIE CRONICI GURA OCNITEI-FEBRUARIE 2024**

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Val inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	CMA AM nr. 115/24.10.2022	Metoda de analiza
pH	Iesire statie	unitati ph	7,7	-	-	1	0	6,5-8,5	SR ISO 10523/2012
Consum chimic de oxigen		mg O ₂ /l	276,13	-	-	1	0	500	SR ISO 6060/1996
Amoniu		mg/l	28,21	-	-	1	0	30	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	6,79	-	-	1	0	25	SR EN 903/2003
Materii totale in suspensie		mg/l	186	-	-	1	0	350	SR EN 872/2005
Reziduu filtrabil		mg/l	637	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)		mg O ₂ /l	132	-	-	1	0	300	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	30	SR 7587/1996
Fosfor total		mg/l	4,7	-	-	1	0	5	SR EN ISO 6878/2005
Cloruri		mg/l	41	-	-	1	0	500	SR EN ISO 10304-1/2009

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare -nr. 312/29.02.2024

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro


Indicatori chimici monitorizati la IESIREA din Statia de Epurare **SPITAL DE PSIHIATRIE CRONICI GURA OCNITEI-MARTIE 2024**

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Val inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	CMA AM nr. 115/24.10.2022	Metoda de analiza
pH	lesire statie	unitati ph	7,8	-	-	1	0	6,5-8,5	SR ISO 10523/2012
Consum chimic de oxigen		mg O ₂ /l	376,22	-	-	1	0	500	SR ISO 6060/1996
Amoniu		mg/l	27,24	-	-	1	0	30	SR ISO 7150-1/2001
Agenti de suprafata anionici		mg/l	1,08	-	-	1	0	25	SR EN 903/2003
Materii totale in suspensie		mg/l	195	-	-	1	0	350	SR EN 872/2005
Reziduu filtrabil		mg/l	605	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)		mg O ₂ /l	234	-	-	1	0	300	SR EN ISO 5815-1: 2020
Substante extractibile		mg/l	<20	-	-	1	0	30	SR 7587/1996
Fosfor total		mg/l	4,67	-	-	1	0	5	SR EN ISO 6878/2005
Cloruri		mg/l	47	-	-	1	0	500	SR EN ISO 10304-1/2009

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura



COMPANIA DE APA
TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 **0800800168** (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Conform Raport de incercare – Nr. 359/11.03.2024