

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

[www.catd.ro](http://www.catd.ro) [secretariat@catd.ro](mailto:secretariat@catd.ro)

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **SPITAL PNEUMOLOGIE MOROIENI** - MARTIE 2024

Tip proba-apa uzata

Indicator de Calitate	Punct prelevare	UM	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. Mas.	Nr.Depasiri CMA / VL	CMA / VL. conf. Autoriz. Mediu 69/03.06.2022	Metoda Analiza STAS - ISO
pH	lesire statie	Unit. pH	7,2	–	–	1	0	6,5 – 8,5	SR EN ISO 10523: 2012
CCO – Cr.	lesire statie	mg / L	<30	–	–	1	0	125	SR ISO 6060: 1996
Agenti de suprafata anionici	lesire statie	mg / L	<0,1	–	–	1	0	0,5	SR EN 903: 2003
MTS	lesire statie	mg / L	5,8	–	–	1	0	60	SR EN 872: 2005
Reziduu filtrabil	lesire statie	mg / L	254	–	–	1	0	1500	STAS 9187:1984
CBO <sub>5</sub>	lesire statie	mg / L	3	–	–	1	0	25	SR EN ISO 5815-1:2020
SE	lesire statie	mg / L	<20	–	–	1	0	20	SR 7587:1996
Fosfor total	lesire statie	mg / L	0,16	–	–	1	0	2	SR EN ISO 6878:2005
Cloruri	lesire statie	mg / L	250	–	–	1	0	500	SR EN ISO 10304:2009
Azot total	lesire statie	mg / L	2,5	–	–	1	0	15	SR EN ISO 20236:2021

Conform raport de incercare nr. 412/20.03.2024