



REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **VISINESTI-FEBRUARIE 2024**

Tip proba-apa uzata

Indicator analizat	Punct de Prelevare	U.M	Val inregistrata	Val maxima	Val minima	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conf.AM 46/24.03.2020	Metoda de analiza
Ph	lesire statie	Unitati Ph	7,5(20,0°C)	-	-	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS	lesire statie	Mg/l	12	-	-	1	0	35	SR EN 872/2005
CBO ₅	lesire statie	mg/l	6	-	-	1	0	25	SR EN ISO 5815-1: 2020
CCO-Cr	lesire statie	mg/l	30,87	-	-	1	0	125	SR EN ISO 6060/1996
SE	lesire statie	Mg/l	<20	-	-	1	0	20	SR ISO 7587/1996
Reziduu fix	lesire statie	Mg/l	423	-	-	1	0	2000	STAS 9187/84
Detergenti	lesire statie	Mg/l	0,22	-	-	1	0	0,5	SR EN 903/2003
Amoniu	lesire statie	Mg/l	1,29	-	-	1	0	3	SR ISO 7150-1/2001

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare -nr. 241/21.02.2024