

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL I 2024

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **VULCANA PANDELE** IANUARIE 2024


Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 56/08.04.2019	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7,6	-	-	1	0	6,5-8,5	SR EN ISO 10523:2012
MTS		mg/l	5,8	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	5	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	564	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	0,15	-	-	1	0	0,5	SR EN 903:2003
Amoniu		mg/l	2,09	-	-	1	0	3	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare - Nr. 77/ 22.01.2024



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **VULCANA PANDELE** – FEBRUARIE 2024


Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 56/08.04.2019	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7,5	-	-	1	0	6.5-8.5	SR ENISO 10523:2012
MTS		mg/l	6,4	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	5	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	30,87	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	397	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	0,25	-	-	1	0	0,5	SR EN 903:2003
Amoniu		mg/l	0,41	-	-	1	0	3,0	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform Raport de incercare – Nr.233/20.02.2024



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774

www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **VULCANA PANDELE** - MARTIE 2024

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 56/08.04.2019	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7,6	-	-	1	0	6.5-8.5	SR EN ISO 10523:2012
MTS		mg/l	6,6	-	-	1	0	60	SR EN 872:2005
CBO ₅		mg/l	4	-	-	1	0	25	SR EN ISO 5815-1:2020
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060:1996
SE		mg/l	<20	-	-	1	0	20	SR 7587:1996
Reziduu filtrabil		mg/l	183	-	-	1	0	2000	STAS 9187:1984
Agenti de suprafata anionici		mg/l	<0,1	-	-	1	0	0,5	SR EN 903:2003
Amoniu		mg/l	0,39	-	-	1	0	3	SR ISO 7150-1:2001

CMA - concentratie maxima admisa sau VL - valoare limita

U.M. - unitate de masura

Conform Raport de incercare - nr.363/12.03.2024