

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Branesti** - Aprilie 2021

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 38/30.05.2018	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7.7	–	–	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	8.6	–	–	1	0	60	SR EN 872/2005
CBO ₅		mg/l	5	–	–	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	32.91	–	–	1	0	125	SR ISO 6060/96
SE		mg/l	<20	–	–	1	0	20	SR 7587/96
Reziduu fix		mg/l	329	–	–	1	0	2000	STAS 9187/84
Detergenti		mg/l	< 0.1	–	–	1	0	0.5	SR EN 903/2003
Amoniu		mg/l	0.68	–	–	1	0	3.0	SR EN ISO 6878/2005

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Branesti** - MAI 2021

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 8630/15.11.2011	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7.6	–	–	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	14	–	–	1	0	60	SR EN 872/2005
CBO ₅		mg/l	4	–	–	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	31.10	–	–	1	0	125	SR ISO 6060/96
SE		mg/l	<20	–	–	1	0	20	SR 7587/96
Reziduu fix		mg/l	184	–	–	1	0	2000	STAS 9187/84
Detergenti		mg/l	0.13	–	–	1	0	0.5	SR EN 903/2003
Amoniu		mg/l	1.07	–	–	1	0	3.0	SR EN ISO 6878/2005