

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare BREZOAELI - APRILIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masuratori	Nr.depasiri	CMA/Val Conf. autorizatiei deMediu Nr.84/17.05.2019	Metoda de analiza STAS
PH	iesire statie	Unit ph	7,5	7,5	7,5	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	43,94	43,94	43,94	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	0,12	0,12	0,12	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	9,4	9,4	9,4	1	0	35	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	703	703	703	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	13	13	13	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	<20	<20	1	0	20	SR 7587:1996
Amoniu	iesire statie	mg/l	1,91	1,91	1,91	1	0	2,0	SR ISO 7150-1;2001

Conform Raport de incercare nr.489 din 19.04.2021

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare BREZOAELE - MAI 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masuratori iesire	Nr.depasiri	CMA/Val Conf. autorizatiei deMediu Nr.84/17.05.2019	Metoda de analiza STAS
PH	iesire statie	Unitph	8,1	8,1	8,1	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	34,76	34,76	34,76	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	<0,1	<0,1	<0,1	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	7,8	7,8	7,8	1	0	35	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	630	630	630	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	5	5	5	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	<20	<20	1	0	20	SR 7587:1996
Amoniu	iesire statie	mg/l	0,13	0,13	0,13	1	0	2,0	SR ISO 7150-1;2001

Conform Raport de incercare nr.633 din 24.05.2021

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare BREZOAELE - IUNIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masuratori	Nr.depasiri	CMA/Val Conf. autorizatiei deMediu Nr.84/17.05.2019	Metoda de analiza STAS
PH	iesire statie	Unitph	7,6	–	–	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	<30	–	–	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	0,29	–	–	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	11	–	–	1	0	35	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	455	–	–	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	6	–	–	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	–	–	1	0	20	SR 7587:1996
Amoniu	iesire statie	mg/l	1,94	–	–	1	0	2,0	SR ISO 7150-1;2001

Conform Raport de incercare nr.773 din 22.06.2021