

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Cojasca-MAI 2021**

Tip proba-apa uzata

| Indicator de analiza | Punct de prelevare | U.M. | Valoare inregistrata | Val maxima | Val minima | Nr. mas. | Nr. dep. CMA | CMA AM nr. 19/29.01.2021 | Metoda de analiza |
|--|--------------------|------------|----------------------|------------|------------|----------|--------------|--------------------------|--------------------|
| pH | lesire statie | unitati ph | 7.8 | - | - | 1 | 0 | 6.5-8.5 | SR ISO 10523/2012 |
| Consum chimic de oxigen | lesire statie | mg/l | < 30 | - | - | 1 | 0 | 125 | SR ISO 6060/1996 |
| Amoniu | lesire statie | mg/l | 0.31 | - | - | 1 | 0 | 3 | SR ISO 7150-1/2001 |
| Agenti de suprafata anionici | lesire statie | mg/l | 0.26 | - | - | 1 | 0 | 0.5 | SR EN 903/2003 |
| Materi totale in suspensie | lesire statie | mg/l | 8.6 | - | - | 1 | 0 | 60 | SR EN 872/2005 |
| Reziduu filtrabil | lesire statie | mg/l | 294 | - | - | 1 | 0 | 2000 | STAS 9187/1984 |
| Consum biochimic de oxigen dupa 5 zile (CBO ₅) | lesire statie | mg/l | 5 | - | - | 1 | 0 | 25 | SR EN 1899-1/2003 |
| Substante extractibile | lesire statie | mg/l | < 20 | - | - | 1 | 0 | 20 | SR 7587/1996 |