

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Comisani-MAI** 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val Maxima	Val Minima	Nr. Mas	Nr. Dep. CMA	CMA AM nr. 8404/12.01.2011	Metoda de analiza
pH	lesire statie	unitati ph	7.9	7.9	7.9	1	0	6.5-8.5	SR ISO 10523/2012
Consum chimic de oxigen	lesire statie	mg/l	< 30	< 30	< 30	1	0	125	SR ISO 6060/1996
Amoniu	lesire statie	mg/l	0.45	0.45	0.45	1	0	3	SR ISO 7150-1/2001
Agenti de suprafata anionici	lesire statie	mg/l	0.28	0.28	0.28	1	0	0.5	SR EN 903/2003
Materii totale in suspensie	lesire statie	mg/l	3.2	3.2	3.2	1	0	60	SR EN 872/2005
Reziduu filtrabil	lesire statie	mg/l	377	377	377	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO <sub>5</sub> )	lesire statie	mg/l	3	3	3	1	0	25	SR EN 1899-1/2003
Substante extractibile	lesire statie	mg/l	< 20	< 20	< 20	1	0	20	SR 7587/1996

Conform Raport de incercare –nr. 616/18.05.2021