

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Dobra** -Aprilie 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val Maxima	Val Minima	Nr. Mas.	Nr. dep. CMA's au VL	CMA/VL AM nr. 30/27.02.2019	Metoda de analiza
pH	lesire statie	unitati ph	7.7	-	-	1	0	6.5-8.5	SR ISO 10523/2012
Consum chimic de oxigen	lesire statie	mg/l	< 30	-	-	1	0	125	SR ISO 6060/1996
Amoniu	lesire statie	mg/l	0.26	-	-	1	0	3	SR ISO 7150-1/2001
Agenti de suprafata anionici	lesire statie	mg/l	0.13	-	-	1	0	0.5	SR EN 903/2003
Materii totale in suspensie	lesire statie	mg/l	4.8	-	-	1	0	60	SR EN 872/2005
Reziduu filtrabil	lesire statie	mg/l	401	-	-	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO <sub>5</sub> )	lesire statie	mg/l	6	-	-	1	0	25	SR EN 1899-1/2003
Substante extractibile	lesire statie	mg/l	< 20	-	-	1	0	20	SR 7587/1996

Conform Raport de incercare –nr.454/12.04.2021