

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare FIENI - APRILIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	UM	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. Mas.	Nr.Depasiri CMA / VL	CMA / VL. conf. Autoriz. Mediu nr. 86 / 08.11.2016	Metoda Analiza STAS - ISO
pH	lesire statie	Unit. pH	7,7	–	–	1	-	6,5 – 8,5	SR ISO 10523: 2012
CCO – Cr.	lesire statie	mg / L	<30	–	–	1	-	125	SR ISO 6060: 1996
NH ₄	lesire statie	mg / L	0,17	–	–	1	-	2	SR ISO 7150-1: 2001
Detergenti	lesire statie	mg / L	< 0,1	–	–	1	-	0,5	SR EN 903: 2003
MTS	lesire statie	mg / L	5,2	–	–	1	-	35	SR EN 872: 2005
Reziduu filtrabil	lesire statie	mg / L	289	–	–	1	-	2000	STAS 9187: 1984
CBO ₅	lesire statie	mg / L	3	–	–	1	-	25	SR EN 1899-1: 2003
SE	lesire statie	mg / L	<20	–	–	1	-	20	SR 7587: 1996

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare FIENI - MAI 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	UM	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. Mas.	Nr.Depasiri CMA / VL	CMA / VL. conf. Autoriz. Mediu nr. 86 / 08.11.2016	Metoda Analiza STAS - ISO
pH	lesire statie	Unit. pH	7,6	–	–	1	-	6,5 – 8,5	SR ISO 10523: 2012
CCO – Cr.	lesire statie	mg / L	<30	–	–	1	-	125	SR ISO 6060: 1996
NH ₄	lesire statie	mg / L	0,37	–	–	1	-	2	SR ISO 7150-1: 2001
Detergenti	lesire statie	mg / L	0,15	–	–	1	-	0,5	SR EN 903: 2003
MTS	lesire statie	mg / L	5,6	–	–	1	-	35	SR EN 872: 2005
Reziduu filtrabil	lesire statie	mg / L	415	–	–	1	-	2000	STAS 9187: 1984
CBO ₅	lesire statie	mg / L	4	–	–	1	-	25	SR EN 1899-1: 2003
SE	lesire statie	mg / L	<20	–	–	1	-	20	SR 7587: 1996

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare FIENI - IUNIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	UM	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. Mas.	Nr.Depasiri CMA / VL	CMA / VL. conf. Autoriz. Mediu nr. 86 / 08.11.2016	Metoda Analiza STAS - ISO
pH	lesire statie	Unit. pH	7,9	–	–	1	-	6,5 – 8,5	SR ISO 10523: 2012
CCO – Cr.	lesire statie	mg / L	<30	–	–	1	-	125	SR ISO 6060: 1996
NH ₄	lesire statie	mg / L	0,38	–	–	1	-	2	SR ISO 7150-1: 2001
Detergenti	lesire statie	mg / L	<0.1	–	–	1	-	0,5	SR EN 903: 2003
MTS	lesire statie	mg / L	5,2	–	–	1	-	35	SR EN 872: 2005
Reziduu filtrabil	lesire statie	mg / L	378	–	–	1	-	2000	STAS 9187: 1984
CBO ₅	lesire statie	mg / L	4	–	–	1	-	25	SR EN 1899-1: 2003
SE	lesire statie	mg / L	<20	–	–	1	-	20	SR 7587: 1996