

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare Ludesti - APRILIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masuratori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 8564 din 10.08.2011	Metoda de analiza (STAS,ISO)
Ph	Iesire statie	Unitati pH	7,8	—	—	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	Iesire statie	mg/l	40,89	—	—	1	0	125	SR ISO 6060:1996
Amoniu	Iesire statie	mg/l	0,46	—	—	1	0	3	SR ISO 7150-1:2001
Agenti de suprafata anionici	Iesire statie	mg/l	0,13	—	—	1	0	0,5	SR EN 903:2003
MTS	Iesire statie	mg/l	12	—	—	1	0	60	SR EN 872:2005
Reziduu filtrabil	Iesire statie	mg/l	692	—	—	1	0	1000	STAS 9187:1984
CBO5	Iesire statie	mg/l	11	—	—	1	0	25	SR EN 1899-1:2003
Substanta extractibila	Iesire statie	mg/l	< 20	—	—	1	0	20	SR 7587:1996

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare Ludesti - MAI 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 8564 din 10.08.2011	Metoda de analiza (STAS,ISO)
Ph	Iesire statie	Unitati pH	8	—	—	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	Iesire statie	mg/l	< 30	—	—	1	0	125	SR ISO 6060:1996
Amoniu	Iesire statie	mg/l	0,87	—	—	1	0	3	SR ISO 7150-1:2001
Agenti de suprafata anionici	Iesire statie	mg/l	0,17	—	—	1	0	0,5	SR EN 903:2003
MTS	Iesire statie	mg/l	3,8	—	—	1	0	60	SR EN 872:2005
Reziduu filtrabil	Iesire statie	mg/l	251	—	—	1	0	1000	STAS 9187:1984
CBO5	Iesire statie	mg/l	4	—	—	1	0	25	SR EN 1899-1:2003
Substanta extractibila	Iesire statie	mg/l	< 20	—	—	1	0	20	SR 7587:1996

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare Ludesti - IUNIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masuratori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 8564 din 10.08.2011	Metoda de analiza (STAS,ISO)
Ph	Iesire statie	Unitati pH	7,6	—	—	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	Iesire statie	mg/l	38,66	—	—	1	0	125	SR ISO 6060:1996
Amoniu	Iesire statie	mg/l	1,23	—	—	1	0	3	SR ISO 7150-1:2001
Agenti de suprafata anionici	Iesire statie	mg/l	0,16	—	—	1	0	0,5	SR EN 903:2003
MTS	Iesire statie	mg/l	12	—	—	1	0	60	SR EN 872:2005
Reziduu filtrabil	Iesire statie	mg/l	263	—	—	1	0	1000	STAS 9187:1984
CBO5	Iesire statie	mg/l	12	—	—	1	0	25	SR EN 1899-1:2003
Substanta extractibila	Iesire statie	mg/l	< 20	—	—	1	0	20	SR 7587:1996