

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare MORENI - APRILIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conform AM 50/19.05.2016 rev. 30.01.2018	Metoda de analiza
Ph	Iesire statie	Unitati Ph	7,8(20,0°C)	—	—	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS		Mg/l	21	—	—	1	0	35	SR EN872/2005
CBO <sub>5</sub>		mgO <sub>2</sub> /dm <sup>3</sup>	12	—	—	1	0	25	SR EN1899/2003
CCO-Cr		mgO <sub>2</sub> /dm <sup>3</sup>	42,45	—	—	1	0	125	SR EN ISO 6060/1996
SE		Mg/l	<20	—	—	1	0	20	SR ISO 7587/1996
Reziduu fix		Mg/l	541	—	—	1	0	2000	STAS 9187/84
Detergenti		Mg/l	0.23	—	—	1	0	0,5	SR EN 903/2003
Fosfor total		Mg/l	1,13	—	—	1	0	2	SR EN ISO 6878/2005
Azot total		Mg/l	15	—	—	1	0	15	SR EN 12260/2008

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare MORENI - MAI 2021

Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conform AM 50/19.05.2016 rev. 30.01.2018	Metoda de analiza
Ph	Iesire statie	Unitati Ph	7,8(20,0°C)	—	—	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS		Mg/l	7,4	—	—	1	0	35	SR EN872/2005
CBO <sub>5</sub>		mgO <sub>2</sub> /dm <sup>3</sup>	7	—	—	1	0	25	SR EN1899/2003
CCO-Cr		mgO <sub>2</sub> /dm <sup>3</sup>	<30	—	—	1	0	125	SR EN ISO 6060/1996
SE		Mg/l	<20	—	—	1	0	20	SR ISO 7587/1996
Reziduu fix		Mg/l	761	—	—	1	0	2000	STAS 9187/84
Detergenti		Mg/l	0,12	—	—	1	0	0,5	SR EN 903/2003
Fosfor total		Mg/l	0,62	—	—	1	0	2	SR EN ISO 6878/2005
Azot total		Mg/l	9	—	—	1	0	15	SR EN 12260/2008

Conform raport de incercare nr.577/11.05.2021

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare MORENI – IUNIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de Prelevare	U.M	Valoare inregistrata	Valoare maxima	Valoare minima	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conform AM 50/19.05.2016 rev. 30.01.2018	Metoda de analiza
Ph	Iesire statie	Unitati Ph	7,9(20,0°C)	—	—	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS		Mg/l	16	—	—	1	0	35	SR EN872/2005
CBO <sub>5</sub>		mgO <sub>2</sub> /dm <sup>3</sup>	6	—	—	1	0	25	SR EN1899/2003
CCO-Cr		mgO <sub>2</sub> /dm <sup>3</sup>	30,87	—	—	1	0	125	SR EN ISO 6060/1996
SE		Mg/l	<20	—	—	1	0	20	SR ISO 7587/1996
Reziduu fix		Mg/l	407	—	—	1	0	2000	STAS 9187/84
Detergenti		Mg/l	<0,1	—	—	1	0	0,5	SR EN 903/2003
Fosfor total		Mg/l	0,31	—	—	1	0	2	SR EN ISO 6878/2005
Azot total		Mg/l	8,3	—	—	1	0	15	SR EN 12260/2008

Conform raport de incercare 744/14.06.2021