

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare Petresti - APRILIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 9030 din 16.05.2013	Metoda de analiza (STAS,ISO)
Ph	Iesire statie	Unitati pH	7,7	—	—	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	Iesire statie	mg/l	44,79	—	—	1	0	125	SR ISO 6060:1996
Amoniu	Iesire statie	mg/l	0,69	—	—	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	Iesire statie	mg/l	< 0,1	—	—	1	0	0,5	SR EN 903:2003
MTS	Iesire statie	mg/l	16	—	—	1	0	60	SR EN 872:2005
Reziduu filtrabil	Iesire statie	mg/l	623	—	—	1	0	2000	STAS 9187:1984
CBO5	Iesire statie	mg/l	14	—	—	1	0	25	SR EN 1899-1:2003
Substanta extractibila	Iesire statie	mg/l	< 20	—	—	1	0	20	SR 7587:1996

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare Petresti - MAI 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 9030 din 16.05.2013	Metoda de analiza (STAS,ISO)
Ph	Iesire statie	Unitati pH	7,8	—	—	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	Iesire statie	mg/l	< 30	—	—	1	0	125	SR ISO 6060:1996
Amoniu	Iesire statie	mg/l	1,74	—	—	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	Iesire statie	mg/l	1,02	—	—	1	1	0,5	SR EN 903:2003
MTS	Iesire statie	mg/l	5,2	—	—	1	0	60	SR EN 872:2005
Reziduu filtrabil	Iesire statie	mg/l	227	—	—	1	0	2000	STAS 9187:1984
CBO5	Iesire statie	mg/l	5	—	—	1	0	25	SR EN 1899-1:2003
Substanta extractibila	Iesire statie	mg/l	< 20	—	—	1	0	20	SR 7587:1996

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare Petresti - IUNIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr. masurat ori	Nr. depasiri CMA sau VL	CMA/VL conform AM nr. 9030 din 16.05.2013	Metoda de analiza (STAS,ISO)
Ph	Iesire statie	Unitati pH	7,9	—	—	1	0	6,5 – 8,5	SR ISO 10523/2012
CCO	Iesire statie	mg/l	< 30	—	—	1	0	125	SR ISO 6060:1996
Amoniu	Iesire statie	mg/l	1,11	—	—	1	0	2	SR ISO 7150-1:2001
Agenti de suprafata anionici	Iesire statie	mg/l	0,93	—	—	1	1	0,5	SR EN 903:2003
MTS	Iesire statie	mg/l	4,6	—	—	1	0	60	SR EN 872:2005
Reziduu filtrabil	Iesire statie	mg/l	257	—	—	1	0	2000	STAS 9187:1984
CBO5	Iesire statie	mg/l	7	—	—	1	0	25	SR EN 1899-1:2003
Substanta extractibila	Iesire statie	mg/l	< 20	—	—	1	0	20	SR 7587:1996