

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare POTLOGI - APRILIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masuratori	Nr.depasiri ale CMA	CMA/Val Conf. autorizatiei de Mediu Nr.8/15.01.2019	Metoda de analiza STAS
PH	iesire statie	Unit ph	7,9	–	–	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	<30	–	–	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	<0,1	–	–	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	4,0	–	–	1	0	60	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	304	–	–	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	3	–	–	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	–	–	1	0	20	SR 7587:1996
Fosfor total	iesire statie	mg/l	0,09	–	–	1	0	1,0	SR ISO 6878:2005
Amoniu	iesire statie	mg/l	0,45	–	–	1	0	2,0	SR ISO 7150-1;2001

Conform Raport de incercare nr.488 din 19.04.2021

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare POTLOGI - MAI 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masurat ori	Nr.depasiri ale CMA	CMA/Val Conf. autorizatiei de Mediu Nr.8/15.01.2019	Metoda de analiza STAS
PH	iesire statie	Unitph	7,8	–	–	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	<30	–	–	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	<0,1	–	–	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	2,6	–	–	1	0	60	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	644	–	–	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	2	–	–	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	–	–	1	0	20	SR 7587:1996
Fosfor total	iesire statie	mg/l	0,13	–	–	1	0	1,0	SR ISO 6878:2005
Amoniu	iesire statie	mg/l	0,08	–	–	1	0	2,0	SR ISO 7150-1;2001

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare POTLOGI - IUNIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masuratori	Nr.depasiri	CMA/Val Conf. autorizatiei de Mediu Nr.8/15.01.2019	Metoda de analiza STAS
PH	iesire statie	Unit ph	7,7	–	–	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	<30	–	–	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	0,27	–	–	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	5,0	–	–	1	0	60	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	326	–	–	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	5	–	–	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	–	–	1	0	20	SR 7587:1996
Fosfor total	iesire statie	mg/l	0,14	–	–	1	0	1,0	SR ISO 6878:2005
Amoniu	iesire statie	mg/l	0,05	–	–	1	0	2,0	SR ISO 7150-1;2001

Conform Raport de incercare nr.774 din 22.06.2021