

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Priseaca-MAI** 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Val inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	CMA AM nr. 71/09.08.2016	Metoda de analiza
pH	lesire statie	unitati ph	8.1	–	–	1	0	6.5-8.5	SR ISO 10523/2012
Consum chimic de oxigen	lesire statie	mg/l	<30	–	–	1	0	125	SR ISO 6060/1996
Agenti de suprafata anionici	lesire statie	mg/l	<0.1	–	–	1	0	0.5	SR EN 903/2003
Materii totale in suspensie	lesire statie	mg/l	2.4	–	–	1	0	60	SR EN 872/2005
Reziduu filtrabil	lesire statie	mg/l	385	–	–	1	0	1500	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)	lesire statie	mg/l	3	–	–	1	0	25	SR EN 1899-1/2003
Substante extractibile	lesire statie	mg/l	< 20	–	–	1	0	20	SR 7587/1996
Fosfor total	lesire statie	mg/l	0.09	–	–	1	0	2	SR EN ISO 6878/2005
Cloruri	lesire statie	mg/l	24	–	–	1	0	500	SR EN ISO 1034/2009
Sulfati	lesire statie	mg/l	34	–	–	1	0	600	SR EN ISO 1034/2009
Azot total	lesire statie	mg/l	7.5	–	–	1	0	15	SR EN 12260/2008