

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Pucioasa** - Aprilie 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. Autorizatie Mediu Nr. 120/06.08.2019	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7.7	–	–	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	6.4	–	–	1	0	35	SR EN 872/2005
CBO ₅		mg/l	3	–	–	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	<30	–	–	1	0	125	SR ISO 6060/96
SE		mg/l	< 20	–	–	1	0	20	SR 7587/96
Reziduu fix		mg/l	294	–	–	1	0	2000	STAS 9187/84
Detergenti		mg/l	0.11	–	–	1	0	0.5	SR EN 903/2003
Fosfor total		mg/l	0.6	–	–	1	0	2	SR EN ISO 6878/2005
Azot total		mg/l	1.7	–	–	1	0	15	SR EN 12260/2008

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Pucioasa** – MAI-2021

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 120/06.08.2019	Metoda de analiza (STAS, ISO)
pH	Iesire statie	Unitati ph	7.2	–	–	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	3.8	–	–	1	0	35	SR EN 872/2005
CBO ₅		mg/l	3	–	–	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	<30	–	–	1	0	125	SR ISO 6060/96
SE		mg/l	< 20	–	–	1	0	20	SR 7587/96
Reziduu fix		mg/l	362	–	–	1	0	2000	STAS 9187/84
Detergenti		mg/l	<0.1	–	–	1	0	0.5	SR EN 903/2003
Fosfor total		mg/l	0.74	–	–	1	0	2	SR EN ISO 6878/2005
Azot total		mg/l	4.1	–	–	1	0	15	SR EN 12260/2008

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Pucioasa** – IUNIE-2021

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Valoare inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 120/06.08.2019	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7.7	–	–	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	5.2	–	–	1	0	35	SR EN 872/2005
CBO ₅		mg/l	4	–	–	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	<30	–	–	1	0	125	SR ISO 6060/96
SE		mg/l	< 20	–	–	1	0	20	SR 7587/96
Reziduu fix		mg/l	331	–	–	1	0	2000	STAS 9187/84
Detergenti		mg/l	<0.1	–	–	1	0	0.5	SR EN 903/2003
Fosfor total		mg/l	0.96	–	–	1	0	2	SR EN ISO 6878/2005
Azot total		mg/l	2.3	–	–	1	0	15	SR EN 12260/2008