

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Spital de Psihiatrie Cronici Gura Ocnitei-MAI 2021**

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Val inregistrata	Val maxima	Val minima	Nr. mas.	Nr. dep. CMA	CMA AM nr. 8853/20.09.2012	Metoda de analiza
pH	lesire statie	unitati ph	7.7	–	–	1	0	6.5-8.5	SR ISO 10523/2012
Consum chimic de oxigen	lesire statie	mg/L	62.99	–	–	1	0	125	SR ISO 6060/1996
Agenti de suprafata anionici	lesire statie	mg/l	0.22	–	–	1	0	0.5	SR EN 903/2003
Materii totale in suspensie	lesire statie	mg/l	28	–	–	1	0	60	SR EN 872/2005
Reziduu filtrabil	lesire statie	mg/l	598	–	–	1	0	2000	STAS 9187/1984
Consum biochimic de oxigen dupa 5 zile (CBO <sub>5</sub> )	lesire statie	mg/l	23	–	–	1	0	25	SR EN 1899-1/2003
Substante extractibile	lesire statie	mg/l	< 20	–	–	1	0	20	SR 7587/1996
Fosfor total	lesire statie	mg/l	1.1	–	–	1	0	2	SR EN ISO 6878/2005
Cloruri	lesire statie	mg/l	99	–	–	1	0	500	SR EN ISO 1034/2009
Azot total	lesire statie	mg/l	14	–	–	1	0	15	SR EN 12260/2008