



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL al patrulea 2022

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **TARGOVISTE NORD-OCTOMBRIE 2022**

Tip proba-apa uzata

Indicatori de analiza	Punct de prelevare	UM	Val medie	Val max.	Val min.	Nr. mas	Nr. dep CMA	CMA cfm. A.M. nr. 124/14.07.2014 rev 13.01.2021	Metoda de analiza
pH	lesire Statie	Unitati pH	7,8	7,9	7,7	2	0	6,5-8,5	SR ISO 10523:2012
Consum chimic de oxigen	lesire Statie	mg/L	<30	<30	<30	2	0	125	SR ISO 6060:1996
Agenti de suprafata anionici	lesire Statie	mg/L	0,12	0,14	0,10	2	0	0,5	SR EN 903:2003
Materii totale in suspensie	lesire Statie	mg/L	4,1	4,2	4	2	0	35	SR EN 872:2005
Reziduu filtrabil	lesire Statie	mg/L	645	700	589	2	0	2000	STAS 9187:1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)	lesire Statie	mg/L	4	5	3	2	0	25	SR EN ISO 5815-1:2020
Substante extractibile	lesire Statie	mg/L	<20	<20	<20	2	0	20	SR 7587:1996
Fosfor total	lesire Statie	mg/L	0,16	0,16	0,15	2	0	1	SR EN ISO 6878:2005
Azot total	lesire Statie	mg/L	7,95	8,5	7,4	2	0	10	SR EN 12260:2008- Anexa A
Nichel	lesire Statie	mg/L	-	-	-	-	-	0,5	SR EN ISO 8288:2001
Zinc	lesire Statie	mg/L	-	-	-	-	-	0,5	SR EN ISO 8288:2001
Crom total	lesire Statie	mg/L	-	-	-	-	-	1	SR EN ISO 20236:2021

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform rapoartelor de incercare nr. 1371/24.10.2022 si 1405/31.10.2022



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **TARGOVISTE NORD-NOIEMBRIE 2022**

Tip proba-apa uzata

Indicatori de analiza	Punct de prelevare	UM	Val medie	Val max.	Val min.	Nr. mas	Nr. dep CMA	CMA cfm. A.M. nr. 124/14.07.2014 rev 13.01.2021	Metoda de analiza
pH	lesire Statie	Unitati pH	7,65	7,7	7,6	2	0	6,5-8,5	SR ISO 10523:2012
Consum chimic de oxigen	lesire Statie	mg/L	<30	<30	<30	2	0	125	SR ISO 6060:1996
Agenti de suprafata anionici	lesire Statie	mg/L	0,12	0,14	0,10	2	0	0,5	SR EN 903:2003
Materii totale in suspensie	lesire Statie	mg/L	5,7	6,2	5,2	2	0	35	SR EN 872:2005
Reziduu filtrabil	lesire Statie	mg/L	450	574	326	2	0	2000	STAS 9187:1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)	lesire Statie	mg/L	8	12	4	2	0	25	SR EN ISO 5815-1:2020
Substante extractibile	lesire Statie	mg/L	<20	<20	<20	2	0	20	SR 7587:1996
Fosfor total	lesire Statie	mg/L	0,17	0,22	0,11	2	0	1	SR EN ISO 6878:2005
Azot total	lesire Statie	mg/L	8,2	8,4	8	2	0	10	SR EN ISO 20236:2021
Nichel	lesire Statie	mg/L	<0,1	<0,1	<0,1	1	0	0,5	SR EN ISO 8288:2001
Zinc	lesire Statie	mg/L	<0,05	<0,05	<0,05	1	0	0,5	SR EN ISO 8288:2001
Crom total	lesire Statie	mg/L	<0,5	<0,5	<0,5	1	0	1,0	SR EN ISO 1233:2003

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform rapoartelor de incercare nr. 1511/16.11.2022 si nr 1534/23.11.2022



COMPANIA DE APA TARGOVISTE-DAMBOVITA



Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **TARGOVISTE NORD-DECEMBRIE 2022**

Tip proba-apa uzata

Indicatori de analiza	Punct de prelevare	UM	Val medie	Val max.	Val min.	Nr. mas	Nr. dep CMA	CMA cfm. A.M. nr. 124/14.07.2014 rev 13.01.2021	Metoda de analiza
pH	lesire Statie	Unitati pH	7,6	7,7	7,5	2	0	6,5-8,5	SR ISO 10523:2012
Consum chimic de oxigen	lesire Statie	mg/L	30,38	30,77	<30	2	0	125	SR ISO 6060:1996
Agenti de suprafata anionici	lesire Statie	mg/L	0,14	0,14	0,14	2	0	0,5	SR EN 903:2003
Materii totale in suspensie	lesire Statie	mg/L	6,3	7,4	5,2	2	0	35	SR EN 872:2005
Reziduu filtrabil	lesire Statie	mg/L	664,5	665	664	2	0	2000	STAS 9187:1984
Consum biochimic de oxigen dupa 5 zile (CBO ₅)	lesire Statie	mg/L	4	4	4	2	0	25	SR EN ISO 5815-1:2020
Substante extractibile	lesire Statie	mg/L	<20	<20	<20	2	0	20	SR 7587:1996
Fosfor total	lesire Statie	mg/L	0,21	0,24	0,17	2	0	1,0	SR EN ISO 6878:2005
Azot total	lesire Statie	mg/L	8,25	8,9	7,6	2	0	10	SR EN ISO 20236:2021
Nichel	lesire Statie	mg/L	-	-	-	-	-	0,5	SR EN ISO 8288:2001
Zinc	lesire Statie	mg/L	-	-	-	-	-	0,5	SR EN ISO 8288:2001
Crom total	lesire Statie	mg/L	-	-	-	-	-	1,0	SR EN ISO 1233:2003

CMA - concentratie maxima admisa sau VL – valoare limita

U.M. - unitate de masura

Conform rapoartelor de incercare nr. 1616/14.12.2022 si nr. 1668/21.12.2022