

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare TITU - APRILIE 2021

Tip proba-apa uzata

Indicator de analiza	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masuratori	Nr.depasiri	CMA/Val Conf. autorizatiei de mediu nr.74/22.08.2016	Metoda de analiza STAS
PH	iesire statie	Unitph	7,8	–	–	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	<30	–	–	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	0,12	–	–	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	6,4	–	–	1	0	35	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	493	–	–	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	3	–	–	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	–	–	1	0	20	SR 7587:1996
Fosfor total	iesire statie	mg/l	0,11	–	–	1	0	2	SR ISO 6878:2005
Cloruri	iesire statie	mg/l	93	–	–	1	0	500	SR EN ISO10304/2009
Sulfati	iesire statie	mg/l	110	–	–	1	0	600	SR EN ISO10304/2009
Azot total	iesire statie	mg/l	4,0	–	–	1	0	15	SR EN 12260:2008-Anexa A

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare TITU - MAI 2021

Tip proba-apa uzata

Indicator de analiza (cf prevederi autorizatii)	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masur atori	Nr.depasiri	CMA/Val Conf. autorizatiei de mediu nr.74/22.08.2016	Metoda de analiza STAS
PH	iesire statie	Unitph	7,4	–	–	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	<30	–	–	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	<0,1	–	–	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	5,4	–	–	1	0	35	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	638	–	–	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	2	–	–	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	–	–	1	0	20	SR 7587:1996
Fosfor total	iesire statie	mg/l	0,18	–	–	1	0	2	SR ISO 6878:2005
Cloruri	iesire statie	mg/l	97	–	–	1	0	500	SR EN ISO10304/2009
Sulfati	iesire statie	mg/l	100	–	–	1	0	600	SR EN ISO10304/2009
Azot total	iesire statie	mg/l	4,3	–	–	1	0	15	SR EN 12260:2008- Anexa A

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare TITU - IUNIE 2021

Tip proba-apa uzata

Indicator de analiza (cf prevederi autorizatii)	Punct de prelevare	U.M.	Valoare inregistrata	Valoare maxima	Valoare minima	Nr masuratori	Nr.depasiri	CMA/Val Conf. autorizatiei de mediu nr.74/22.08.2016	Metoda de analiza STAS
PH	iesire statie	Unitph	7,7	–	–	1	0	6.5-8.5	SR EN ISO10523-2012
CCO-CR	iesire statie	mg/l	<30	–	–	1	0	125	SR ISO 6060/96
Agenti de suprafata anionici	iesire statie	mg/l	0,16	–	–	1	0	0.5	SR EN 903:2003
MTS	iesire statie	mg/l	9,0	–	–	1	0	35	SR EN 872:2009
Reziduu filtrabil	iesire statie	mg/l	401	–	–	1	0	2000	STAS 9187:1984
CBO5	iesire statie	mg/l	4	–	–	1	0	25	SR EN 1899-1:2003
Substanta extractibila	iesire statie	mg/l	<20	–	–	1	0	20	SR 7587:1996
Fosfor total	iesire statie	mg/l	0,13	–	–	1	0	2	SR ISO 6878:2005
Cloruri	iesire statie	mg/l	87	–	–	1	0	500	SR EN ISO10304/2009
Sulfati	iesire statie	mg/l	110	–	–	1	0	600	SR EN ISO10304/2009
Azot total	iesire statie	mg/l	5,9	–	–	1	0	15	SR EN 12260:2008- Anexa A