

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774
www.catd.ro secretariat@catd.ro

REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Visinesti-APRILIE 2021**

Tip proba-apa uzata

Indicator analizat	Punct de Prelevare	U.M	Val inregistrata	Val maxima	Val minima	Numar masuratori	Nr.depasiri CMA / VL	CMA / VL Conf.AM 46/24.03.2020	Metoda de analiza
Ph	Iesire statie	unitati ph	7,6(20,0°C)	–	–	1	0	6,5-8,5	SR EN ISO 10523/2012
MTS		Mg/l	6,8	–	–	1	0	35	SR EN872/2005
CBO ₅		mg/l	3	–	–	1	0	25	SR EN1899/2003
CCO-Cr		mg/l	<30	–	–	1	0	125	SR EN ISO 6060/1996
SE		Mg/l	< 20	–	–	1	0	20	SR ISO 7587/1996
Reziduu fix		Mg/l	409	–	–	1	0	2000	STAS 9187/84
Detergenti		Mg/l	0,29	–	–	1	0	0,5	SR EN 903/2003
Amoniu		Mg/l	0,32	–	–	1	0	3	SR ISO 7150-1/2001