

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

## REZULTATELE MONITORIZARII CALITATII APEI UZATE TRIMESTRUL AL DOILEA 2021

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Vulcana Pandele** - Aprilie 2021

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM Nr. 56/08.04.2019	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7.6	-	-	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	6.2	-	-	1	0	60	SR EN 872/2005
CBO <sub>5</sub>		mg/l	4	-	-	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060/96
SE		mg/l	<20	-	-	1	0	20	SR 7587/96
Reziduu fix		mg/l	242	-	-	1	0	2000	STAS 9187/84
Detergenti		mg/l	<0.1	-	-	1	0	0.5	SR EN 903/2003
Amoniu		mg/l	1.52	-	-	1	0	3.0	SR EN ISO 6878/2005

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Vulcana Pandele** - MAI 2021

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM. Nr. 120/06.08.2019	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7.3	-	-	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	8	-	-	1	0	60	SR EN 872/2005
CBO <sub>5</sub>		mg/l	4	-	-	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060/96
SE		mg/l	<20	-	-	1	0	20	SR 7587/96
Reziduu fix		mg/l	220	-	-	1	0	2000	STAS 9187/84
Detergenti		mg/l	0.27	-	-	1	0	0.5	SR EN 903/2003
Amoniu		mg/l	3	-	-	1	0	3.0	SR EN ISO 6878/2005

Bd. I.C.Bratianu, nr.50, cod postal 130055, Targoviste, jud.Dambovita

Tel. +40245.614403 0800800168 (tel.verde) Fax. +40245.611774  
[www.catd.ro](http://www.catd.ro) secretariat@catd.ro

Indicatori chimici monitorizati la IESIREA din Statia de Epurare **Vulcana Pandele** - IUNIE 2021

Tip proba-apa uzata

Indicator analizat	Punct de prelevare	U.M.	Val. inregistrata	Val. max.	Val. min.	Nr. mas.	Nr. Depasiri CMA sau VL	CMA /VL conf. AM. Nr. 120/06.08.2019	Metoda de analiza (STAS, ISO)
pH	lesire statie	Unitati ph	7.9	-	-	1	0	6.5-8.5	SR ISO 10523/2012
MTS		mg/l	3.2	-	-	1	0	60	SR EN 872/2005
CBO <sub>5</sub>		mg/l	5	-	-	1	0	25	SR EN 1899-1/2003
CCO-Cr		mg/l	<30	-	-	1	0	125	SR ISO 6060/96
SE		mg/l	<20	-	-	1	0	20	SR 7587/96
Reziduu fix		mg/l	268	-	-	1	0	2000	STAS 9187/84
Detergenti		mg/l	0.10	-	-	1	0	0.5	SR EN 903/2003
Amoniu		mg/l	0.31	-	-	1	0	3.0	SR EN ISO 6878/2005